

गावाचा विकास

कार्यालय

देशाचा विकास



गट ग्रामपंचायत उदासा



पंचायत समिती उमरेड, जि. प. नागपूर

सौ. कविता विलासराव दरणे
सरपंच

श्री विठ्ठल माणिक मेश्राम
उपसरपंच

श्री एस. डी. सरादे
सचिव



एक पाऊल स्वच्छतेकडे.....

दि.....12.11.2021



FIRE SAFETY CERTIFICATE

Certified that the society of Franciscan sisters of Christ King India,Goa comprised of 14700 sqm, land owned / occupied by St. Francis Assisi School , Rajurwadi, post Udas, Tal. Umred. Comprised of ground floor and three upper floor = 2939.621 sqm. Have complied with the fire prevention and fire safety requirement in accordance with the rule of state /UT fire service rules and verified by the officers concerned of fire service on 11th September 2021 in the presence of SR Mariam Tirkey principal of St. Francis Assisi School, Rajurwadi, Udas. And that the said above building / premises is safe and fit for occupancy class -II with the effect from 20th September 2021 for a period of ONE years in accordance with rule and subject to compliance of

The conditions Issued on 29/10/2021 at Udas By chief officer of Gram Panchayat, Udas, Tal. Umred.

Signature with seal:

Authority:

Designation:

To,

The principal,

St. Francis Assisi School

Rajurwadi, Udas , Tal. Umred

Dist. - Nagpur

ENDORSEMENT

The no objection certificate issued by department stand cancelled and annulled due to

..... (Reasons to be recorded)

(Name and designation of the authorized signatory)

Dr. Shikha Neelmani
PRINCIPAL /MANAGER
ST FRANCIS ASSISI SCHOOL
RAJURWADI, UMRER

[Signature]
सचिव
ग्राम पंचायत उदासा



PREE ENGINEERING

The Initial Build

License No: - MFS-LA/2019/RD-287

License No: - MFS-LA/2020/RF-241

Date :- 14.12.2021

To,

The Principal,

ST. FRANCIS ASSISI SCHOOL,

Rajurwadi, Umred Road,

Umred.

Subject :- Regarding Installation of Fire Fighting System at ST. FRANCIS ASSISI SCHOOL, Rajurwadi Umred Road, Umred.

Respected Madam,

With reference to aforesaid subject, We PREE ENGINEERING received Work Order of Fire Fighting System on dated 13.11.2021 for ST. FRANCIS ASSISI SCHOOL, Rajurwadi Umred Road, Umred in which we are providing below mention material.

1. Hydrant valve, Hose Reel Drum, Hose Box, RRL Hose Pipe and Short Branch provide to each floor.
2. Manual call point and Electronic Hooter provide to each floor.
3. Fire Piping and cabling work.
4. Fire Pump of capacity 900Lpm provide at terrace.
5. Fire Pump auto manual control panel provide to each floor.
6. Fire alarm panel provide at ground floor.

Out of above mention material below material installed at site.

1. Hydrant valve, Hose Reel Drum, Hose Box, RRL Hose Pipe and Short Branch provide to each floor.
2. Manual call point and Electronic Hooter provide to each floor.
3. Fire Piping and cabling work.

We will require some time for installation of remaining material. Please permit us for the same.

Thanking you,

Yours Faithfully

Mr. Pradeep G. Bokde



Address: -Plot No.2, Laxmi Nivas, Ground Floor, Bapuji Ane Nagar, Nagpur 440017.

Email Id:-preeengineering17@gmail.com, Mb.No.9922481318/9975180837.